

ADDENDUM NO. 1
WATER SYSTEM IMPROVEMENTS
CONTRACT 17-02
MONROE AREA WATER SYSTEM IMPROVEMENTS
LIVINGSTON, TENNESSEE
WAUFORD PROJECT NO. 2058

Date of Addendum: Tuesday, October 10, 2017
Bid Opening: Thursday, October 19, 2017, 2:00 P.M. Local Time

1. Plans, Sheets 4, 5, 6, 9, 10, 11 and 12:


Revise the note for air release valves to read as follows:

***“INSTALL
1 – 1” AIR RELEASE VALVE ASSEMBLY
SEE DETAIL SHEET 14”***


2. Plans, Sheet 14:

Revise as shown on the attached 8 ½” x 11” sheet.

J. R. WAUFORD & COMPANY,
CONSULTING ENGINEERS, INC.



J. Gregory Davenport, P.E.
Tennessee License No. 104881



NOTE

ALL PIPING AND VALVES
SHALL BE 304 STAINLESS STEEL

1- INCH AIR RELEASE VALVE DETAIL

SHEET 14 OF 14		WATER SYSTEM IMPROVEMENTS	
REVISIONS		CONTRACT 17-02	
ADDENDUM NO. 1 10/12/2017 WZM		MONROE AREA WATER SYSTEM IMPROVEMENTS	
		DETAIL SHEET	
		FOR	
		LIVINGSTON, TENNESSEE	
SCALE		 WAUFORD J. R. Wauford & Company, Consulting Engineers, Inc. Nashville, Tennessee (615)883-3243 www.jrwauford.com	DESIGNED DGT
NO SCALE			DRAWN WZM
PROJECT NUMBER		DATE	CHECKED JGD
2058		JUNE 2017	