

ADDENDUM NO. 3
WASTEWATER SYSTEM IMPROVEMENTS
CONTRACT 16-01
WASTEWATER TREATMENT PLANT CHEMICAL FEED AND
STORAGE FACILITIES
LEWISBURG, TENNESSEE
WAUFORD PROJECT NO. 2030
SRF PROJECT NOS. CW6 2017-389 AND SRF 2017-390

Date of Addendum: Thursday, April 26, 2018
Bid Opening: Tuesday, May 1, 2018, 2:00 P.M. Central Time

1. Detailed Specifications, Section 5. Site Development and Building Construction, Paragraph 17. Metal Building and Appurtenances, Subparagraph f. Finishes, Page DS 5-27:

Modify Item (1) Structural Painting as follows:

- “(1) Structural Steel Coating

All structural members shall be galvanized in accordance with ASTM A-25 Coating Class G-90 at the factory.”

2. BID FORM, Page BF-3:

Replace Page BF-3 with the attached BF-3*.

J. R. WAUFORD & COMPANY,
CONSULTING ENGINEERS, INC.



J. Gregory Davenport, P.E.
Tennessee License No. 104881

9. WASTEWATER TREATMENT PLANT CHEMICAL FEED AND STORAGE FACILITIES

ITEM NUMBER	APPROXIMATE QUANTITY	DESCRIPTION WITH UNIT BID PRICE WRITTEN IN WORDS	UNIT PRICE	TOTAL PRICE
1.	Lump Sum	Provide all materials, equipment and labor to construct Chemical Feed and Storage Facilities as shown on the Plans and described in the specifications, complete in place including concrete work, equipment, electrical work and all incidentals related thereto. For _____ _____ Dollars _____ Cents, lump sum		\$ _____
TOTAL BID AMOUNT, CONTRACT 16-01, ITEM 1				\$ _____

10. Vendor Pricing

DeNora Technologies, Inc. price	\$ <u>355,100.00</u>
Southern Flow, Inc. price	\$ <u>39,000.00</u>

(Note: Vendor pricing to be included in the amount for Bid Item No. 1.)