

ADDENDUM NO. 1
SEWER SYSTEM IMPROVEMENTS
CONTRACT 18-02
BUENA VISTA ROAD SEWER PUMPING STATION RENOVATION
TOWN OF HUNTINGDON, TENNESSEE
WAUFORD PROJECT NO. 3643
FIDP PROJECT: GRANGES ALUMINUM

Date of Addendum: Thursday, October 25, 2018

Bid Opening: Tuesday, October 30, 2018, 10:00 A.M. Central Time

1. Detailed Specifications, Section 4. Wastewater Forcemain Pipelines, Piping, Valves and Appurtenances, Paragraph 2c & d. Ductile Iron Pipe (DIP) and Fittings, Page DS 4-2:

All new DIP pipe and fittings shall be specially lined with Protecto 401 or pre-approved equal.

J. R. WAUFORD & COMPANY,
CONSULTING ENGINEERS, INC.



W. Scott Daniel, P.E.

Tennessee License No. 104425