

ADDENDUM NO. 3
CONTRACT 18-02 GIBSON COUNTY INDUSTRIAL PARK ELEVATED TANK
SRF DW6 2019-213, DW7 2019-214 & DWF 2019-215
HUMBOLDT, TENNESSEE
WAUFORD PROJECT NO. 3638

Date of Addendum: Thursday, June 13, 2019
Construction Bid Date: **11:00 AM Local Time, Tuesday, June 18, 2019**

1. Detailed Specifications, Bid Form, Page BF-3;

Delete Item C. The exterior lighting was deleted prior to bidding.

2. Detailed Specifications, Sub-Section 1, "General Scope and Special Provisions", Paragraph 4, "Time of Completion and Liquidated Damages", Page DS 1-2;

The time of construction completion was extended to 540 days in Addendum No. 1. This should have been 450 days. **The contract time for this project shall be 450 days.**

3. Detailed Specifications, Sub-Section 6, "Composite Elevated Water Storage Tank and Foundation", Paragraph 7.F "Appurtenances and Accessories", Sub-Paragraph 5, Page DS 6-12;

Clarification – The walkway shall extend across the support shaft for access to the drain valve as shown on the plans.


4. Detailed Specifications, Sub-Section 6, "Composite Elevated Water Storage Tank and Foundation", Paragraph 8.B "Reinforced Concrete Construction", Sub-Paragraph 2.h, Page DS 6-21;

Replace the first sentence with the following:

"Wall forms shall not be disturbed or removed for a period of **eighteen (18)** hours after concrete placement."

5. Plan Sheet 1, Elevated Tank Site Plan;

Clarification – the asphalt drive at the tank and referenced in the *Legend* as "Proposed Asphalt" is part of this contract.



J. R. WAUFORD & COMPANY,
CONSULTING ENGINEERS, INC.


W. Scott Daniel, P.E.

Tennessee License No. 104425